

# **ELECTRICAL ONLY PLAN REVIEW COMMENTS**

## **New Apartment Complex (Clubhouse)**

**NOTE: Based on original Plan Signature Date, plans have been reviewed using 2020 NEC.**

### **(PR 8298) Clubhouse: Plan Status – Failed**

- Sheet E-1
  - GFI Rcpt req'd near electrical panel. (NEC 210.63(B)).
  - Emergency Ltg required in area with electrical panel. (NC Fire Code 1008.3)
  - Dishwasher required to be GFCI protected. (NEC 210.D)