

SECTION 606
SMOKE DETECTION SYSTEMS CONTROL

606.1 Controls required. Air distribution systems shall be equipped with smoke detectors *listed* and *labeled* for installation in air distribution systems, as required by this section. Duct smoke detectors shall comply with UL 268A. Other smoke detectors shall comply with UL 268.

606.2 Where required. Smoke detectors shall be installed where indicated in Sections 606.2.1 through 606.2.3.

Exception: Smoke detectors shall not be required where air distribution systems are incapable of spreading smoke beyond the enclosing walls, floors and ceilings of the room or space in which the smoke is generated.

10. SHOW ROOM NAMES OF THE AREAS BEING RENOVATED TO ASSIST IN REVIEWING THE OUTSIDE AIR CALCULATIONS.

Floorplans have been updated with room numbers provided by ABSS and will be submitted along with outdoor air tables.

We should have drawings with outdoor air calculations submitted early next week for your review. In the meantime, please let me know if there are any questions/comments based on the above explanations.

Thanks,

Kevin Waters, PE
Vice President / Partner
Systems Contractors, Inc.
PO Box 16023
Greensboro, NC 27416
Office Phone: (336) 763-8974
Mobile Phone: (336) 202-5632
Fax: (336) 449-0297

